



- ▶ COMMUNITY PLANNING
- ▶ HOUSING & COMMUNITY DEVELOPMENT
- ▶ EMERGENCY MANAGEMENT
- ▶ OFFICE OF THE SECRETARY



## Product Approval

USER: Public User

[Product Approval Menu](#) > [Product or Application Search](#) > [Application List](#) > **Application Detail**

FL #	FL8667-R1
Application Type	Editorial Change
Code Version	2004
Application Status	Approved
Comments	
Archived	
Product Manufacturer	Metal Sales Manufacturing Corporation
Address/Phone/Email	7800 State Road 60 Sellersburg, IN 47172 (812) 218-7342 dstermer@metalsales.us.com
Authorized Signature	David Stermer, PE dstermer@metalsales.us.com
Technical Representative	
Address/Phone/Email	
Quality Assurance Representative	
Address/Phone/Email	
Category	Panel Walls
Subcategory	Siding



Compliance Method	Evaluation Report from a Florida Registered Architect or a Licensed Florida Professional Engineer Evaluation Report - Hardcopy Received	
Florida Engineer or Architect Name who developed the Evaluation Report	Bala Sockalingam	
Florida License	PE-62240	
Quality Assurance Entity	Keystone Certifications, Inc.	
Validated By	Yoosef Lavi, P.E.	
Certificate of Independence	<a href="#">FL8667_R1_COI_CertIndependence.pdf</a>	
Referenced Standard and Year (of Standard)	<b><u>Standard</u></b>	<b><u>Year</u></b>
	ASTM E330	2002
Equivalence of Product Standards Certified By		
Sections from the Code		
Product Approval Method	Method 1 Option D	
Date Submitted	06/02/2007	
Date Validated	06/04/2007	
Date Pending FBC Approval	06/05/2007	
Date Approved	06/27/2007	

Summary of Products		
FL #	Model, Number or Name	Description
8667.1	Classic Rib	29 ga., 36" wide wall panel fastened to wood supports
<b>Limits of Use</b> <b>Approved for use in HVHZ:</b> No <b>Approved for use outside HVHZ:</b> Yes <b>Impact Resistant:</b> No <b>Design Pressure:</b> +120 /- 120 <b>Other:</b> Allowable Positive and Negative Design of 120 psf at 24" OC support spacing.		<b>Installation Instructions</b> <a href="#">FL8667_R1_II_1510_4.pdf</a> Verified By: Bala Sockalingam PE 62240 <b>Evaluation Reports</b> <a href="#">FL8667_R1_AE_EvaluationReportC1510_4.pdf</a>

DCA Administration

**Department of Community Affairs**  
**Florida Building Code Online**  
**Codes and Standards**

2555 Shumard Oak Boulevard  
 Tallahassee, Florida 32399-2100

(850) 487-1824, Suncom 277-1824, Fax (850) 414-8436

© 2000-2005 The State of Florida. All rights reserved. [Copyright and Disclaimer](#)

**Product Approval Accepts:**

