



[DCA HOME](#) | [ABOUT DCA](#) | [DCA PROGRAMS](#)



[BCIS Home](#) | [Log In](#) | [Hot Topics](#) | [Submit Surcharge](#) | [Stats & Facts](#) | [Publications](#) | [FBC Staff](#) | [BCIS Site Map](#) | [I](#)



Product Approval  
**USER:** Public User

- ▶ COMMUNITY PLANNING
- ▶ HOUSING & COMMUNITY DEVELOPMENT
- ▶ EMERGENCY MANAGEMENT
- ▶ OFFICE OF THE SECRETARY

[Product Approval Menu](#) > [Product or Application Search](#) > [Application List](#) > **Application Detail**

FL #	FL6710-R1
Application Type	Affirmation
Code Version	2007
Application Status	Approved
Comments	
Archived	<input type="checkbox"/>
Product Manufacturer	Metro Roof Products
Address/Phone/Email	3093 A Industry Street Oceanside, CA 92054 (760) 435-9842 Ext 102 petec@metroroofs.com
Authorized Signature	Peter Croft petec@metroroofs.com
Technical Representative	Joseph Wilson
Address/Phone/Email	3093 'A' Industry Street Oceanside, CA 92054 (760) 435-9842 joew@metroroofproducts.com
Quality Assurance Representative	Ray Pun
Address/Phone/Email	3093 'A' Industry Street Oceanside, CA 92054 (760) 435-9842

rayp@metroroofproducts.com

Category Roofing  
 Subcategory Metal Roofing

Compliance Method Test Report

Testing Lab Underwriters Laboratories Inc.  
 Quality Assurance Entity Underwriters Laboratories Inc.  
 Quality Assurance Contract Expiration Date  
 Validated By Gary W. Walker

Validation Checklist - Hardcopy

Certificate of Independence [FL6710\\_R1\\_COI\\_PRI-CertIndep.p](#)  
[FL6710\\_R1\\_COI\\_ULCertIndep.pd](#)

Referenced Standard and Year (of Standard) **Standard**  
 TAS-100-95  
 TAS-110-95  
 TAS-125-03

Equivalence of Product Standards  
 Certified By

I affirm that there are no changes to the Florida Building Code which affect my product(s) and my product(s) are in compliance with the Florida Building Code.

Product Approval Method Method 1 Option B

Date Submitted 06/04/2008  
 Date Validated 06/04/2008  
 Date Pending FBC Approval  
 Date Approved 06/17/2008

**Summary of Products**

	Model, Number or	
--	------------------	--

FL #	Name	Description
6710.1	Metro Panels - DIRECT to DECK	Stone-coated steel panels install DIRECT to DECK.
<p><b>Limits of Use</b>  <b>Approved for use in HVHZ:</b> Yes  <b>Approved for use outside HVHZ:</b> No  <b>Impact Resistant:</b> N/A  <b>Design Pressure:</b> +0/-153.5  <b>Other:</b> Pressures noted are halved using a design safety factor of 2.</p>		<p><b>Installation Instructions</b>  <a href="#">FL6710_R1_II_FL-6710HVHZ2-06.pdf</a>                      Verified By: Underwriters Lab  <b>Test Reports</b>  <a href="#">FL6710_R1_TR_PRI-TAS100-WindDrSHK12-19-05.pdf</a>  <a href="#">FL6710_R1_TR_PRI-TAS-110SaltSpray1000hr1-5-06.pdf</a>  <a href="#">FL6710_R1_TR_PRI-TAS-110ACCLWeather2000hrs-3-2-06.pdf</a>  <a href="#">FL6710_R1_TR_R19204-UL_06CA38220_7-26-06.pdf</a></p>
6710.2	Metro Panels on - BATTENS	Stone-Coated steel panels on B
<p><b>Limits of Use</b>  <b>Approved for use in HVHZ:</b> Yes  <b>Approved for use outside HVHZ:</b> No  <b>Impact Resistant:</b> N/A  <b>Design Pressure:</b> +0/-78.5  <b>Other:</b> Pressures noted are halved using a design safety factor of 2.</p>		<p><b>Installation Instructions</b>  <a href="#">FL6710_R1_II_FL-6710HVHZ2-06.pdf</a>                      Verified By: Underwriters Lab  <b>Test Reports</b>  <a href="#">FL6710_R1_TR_PRI-TAS100-WindDrRT12-19-05.pdf</a>  <a href="#">FL6710_R1_TR_PRI-TAS-110SaltSpray1000hr1-5-06.pdf</a>  <a href="#">FL6710_R1_TR_PRI-TAS-110ACCLWeather2000hrs-3-2-06.pdf</a>  <a href="#">FL6710_R1_TR_R19204-UL_06CA38220_7-26-06.pdf</a></p>

[Back](#) [Next](#)

[DCA Administration](#)  
*Department of Community Affairs*  
*Florida Building Code Online*  
*Codes and Standards*  
 2555 Shumard Oak Boulevard  
 Tallahassee, Florida 32399-2100  
 (850) 487-1824, Fax (850) 414-8436

© 2000-2005 The State of Florida. All rights reserved. [Copyright and Dis](#)  
 Product Approval Accepts:



 [Click to Verify - This site has chosen a VeriSign SSL Certificate to improve Web site security](#)